

MGV3000 Series

NFPA 99 Medical Vacuum Control Panel

Specifications

- UL 508A listed control panel
- NEMA 12 rated enclosure
- Compliance with NFPA99
- Molded case circuit breaker disconnects for each motor with through the door lockable mechanism
- Dual 120V control circuit transformer with fused primary and secondary circuit with dedicated separate circuit breaker for each pump and control
- Vacuum switch connection for backup system operation should primary control circuit fail*
- Lighted H-O-A switches and magnetic starters with three legs thermal overload for each pump
- 3.5" multicolor touch screen LCD monitor displays operating status, pump run hours, faults, system pressure, alarms and service alert for each pump
- High temperature shutdown for each pump
- PLC controller with control logic to start the lag pump automatically if the lead pump fails to operate. Logic also automatically removes failed or switched off pump from duty sequence.
- All components used in control panel are non-proprietary and can be replaced using standard off the shelf components**
- Able to accept any range of sensors complying to 24VDC 4-20mA standard on site without the use of factory programming
- Alarm logging on HMI
- Normally open and normally closed dry contact for remote monitoring of NFPA 99 alarm points
- Separate push buttons for silencing and resetting the alarms.



Optional Features

- Building automation communication gateway with BacNet® TCP/IP protocol
- 65 KAIC SCCR rating
- Amperage readout for each motor
- Ambient temperature monitoring
- Factory remote connection via secure gateway (with enable/disable switch operated by local personnel)

*Vacuum switches sold separately

** Programable parts will require Axecon downloaded program